

From

To

The Executive Engineer Electrical,
Construction Office, Panjab University,
Chandigarh-160014.

No. Works/.....

Dated.....

Dear Sir,

Please quote your lowest market rate for the supply of the following in a sealed cover marked on the envelope "QUOTATION DUE ON 05.12.2020 at 3:30 P.M.," along with your other terms and conditions of supply, if any.

Subject – Supply of Electrical fixtures for False Ceiling to be done for covering the AC Ducts at Gymnasium hall Building in Panjab University Campus, Sector-14, Chandigarh.

Ch. To:- Rs. 1.50 crore out of Amalgamated Fund of Recurring & non recurring expenditure for the Year 2018-19

Estimated Cost:- Rs. 1, 89,928/-

EMD Amount:- Rs. 4,000/-

S. no.	Description of item	Qty	Unit	Rate
1.	Supply of L.E.D fixture 600mmX600mm 36 W+/- 1W Recess mounted with HET PMMA diffuser with minimum system lumen efficacy of 100 lm/W with CRCA housing with APFC constant Current driver for proper driving of LEDs and P.F.>0.95 with THD<10% ,CRI 80.The LED shall be tested with LM80-08 standard with Useful life of 50000 Hrs at L70. The LED used in the luminarie shall have CCT of 5700 K with CRI of minimum 80. LED used must be tested as per EN62471 for Photo biological Safety of humans. The Input voltage range shall be 150V to 270V. Fixture should have Surge Protection 2kV. Driver Output voltage shall be less than SELV Limits for safe operation and maintenance. Wipro Cat. No: Wipro CRCO10R038HP57GL1 or Equivalent in Philips :RC380B LED42S -6500 G4 L60 W60 PSD OD or Trilux: Entero D IND LED3600-857	34	Nos.	@.....
2.	Supply of L.E.D fixture 15 W +/- 1 W LED Recess Mounted Down lighter Square Shape with minimum system lumen efficacy of 80 lm/W with and P.F.>0.95 with THD<20% ,CRI 80.The LED shall be tested with LM80-08 standard with Useful life of 50000 Hrs at L70. The LEDs used in the luminarie shall have CCT of ANSI Bin 6000 K with CRI of minimum 80. LEDs used must be tested as per EN62471 for Photo biological Safety of humans. The Input voltage range shall be 150V to 270V .Fixture have Surge Protection 2kV .Driver Output voltage shall be less than SELV Limits for safe operation and maintenance. Wipro Cat. No LD81-131-XXX-60-XX or Equivalent in Philips DN097BLED 10S or Trilux :Gleam IND G3 1800-857 ET	50	Nos.	@.....
3.	Supply of IP 20 LED Strip Light 5W/Mtr In Warm White color Temperature including Driver. Wipro Cat No.LS06-005-120-WW-50+LG40-024 (Driver) or equivalent in Philips SKYCove 5M WW with driver or Trilux. (5 mtr roll)	12	Roll (5mtr Each)	@.....

Conditions: -

1. The validity of rates must be at least two months.
2. The supplier shall submit the EMD in form of DD along with quotation in favour of Registrar Panjab University, Chandigarh. Quotation without EMD shall be liable to rejected.
3. The supply be made within 15 days of the receipt of supply order, otherwise EMD will be forfeited.
4. No payment will be made on the Performa invoice. The payment will be made within 60 days through Registrar's office. Condition of payment in cash shall not be accepted.
5. GST Number is mandatory. The firm shall mention their rates of GST if applicable; otherwise quoted rates will be considered inclusive of GST. The rate of GST or any other condition will be mentioned by the firm on its letter head separately.
6. Copy of GST No. to be submitted along with quotation in envelope with name of work, due date, firm name to be written on envelope.
7. 2% GST will be deducted from the bill as applicable.
8. The amount of EMD shall be released after 1 months of the receipt of material.
9. Item wise lowest quoted rates of firms will be considered.
10. F.O.R. P.U. Store, Sector-25, Chandigarh.

Executive Engineer (Elect.),
P.U., Chandigarh